

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0949073	NEWINGTON VA MEDICAL CENTER-BUILDING 2E	NTNC	335	F	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
555 WILLARD AVE				1			
Towns Served: NEWINGTON							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)							
Asbestos (1094)			1 routine (RT) per nine years				
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19						
Total Coliform (3100)			1 routine (RT) per quarter				
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete				
	10/1/16 - 12/31/16		Complete				
	1/1/17 - 3/31/17						
	4/1/17 - 6/30/17						
	7/1/17 - 9/30/17						
Lead And Copper (PBCU)			10 routine (RT) per six months				
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				
Select from Inventory of Active Sampling Points	7/1/16 - 12/31/16		Complete				
	1/1/17 - 6/30/17						
	7/1/17 - 12/31/17						
Physical Parameters (PPS)			1 routine (RT) per quarter				
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				
Select from Inventory of Active Sampling Points	1/1/17 - 3/31/17						
	4/1/17 - 6/30/17						
	7/1/17 - 9/30/17						
Physical Parameters (PPX)			1 routine (RT) per quarter				
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete				
	10/1/16 - 12/31/16		Complete				

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: TREATMENT PLANT (WSFID: 00700)							
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.3 MG/L			2		
Start Date: 12/1/2013	Compliance History:	Operating Limit	Monitoring				
	Monitoring Period	Compliance Status:	Compliance Status:				
	9/1/2016 - 9/30/2016		N				
	10/1/2016 - 10/31/2016		N				
	11/1/2016 - 11/30/2016		N				
	12/1/2016 - 12/31/2016		N				
	1/1/2017 - 1/31/2017						
	2/1/2017 - 2/28/2017						

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2018	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0949073	NEWINGTON VA MEDICAL CENTER-BUILDING 2E	NTNC	335	F	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
555 WILLARD AVE				1			
Towns Served: NEWINGTON							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
00600	DISTRIBUTION SYSTEM	2E-1103	BLDG #2E 1ST FLOOR	A	Y	2		
		2E-2113	BLDG #2E 2ND FLOOR	A	Y	2		
		2E-4111	BLDG #2E EXEC DINING	A	Y	2		
		2E-B130	BLDG #2E BASEMENT	A	Y	2		
		2E-B135B	BLDG #2E PO4/ZN	A	Y	2	Y	
		4	DISTRIBUTION SYSTEM	A	Y	2		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
	UPSTREAM	WITHIN 5 SERVICE CON	A					
00700	TREATMENT PLANT	3	TREATMENT PLANT	A				
58542	INTERCONNECTION - (MDC)							

Certified Operator Information

Water System Facility: TREATMENT PLANT (WSF ID: 00700)			
Facility Classification: CLASS 1 TREATMENT PLANT			
Operator Name	Operator Type	Certification(s)	Certification Expiration
HARKINS, STUART A.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
WITTENZELLNER, ROBERT	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2018

Contact Information

Name		Organization			Job Title	
Mr. Alfred Montoya		Va CT Healthcare System			Assitant Director	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
555 Willard Avenue				Newington	CT	06111
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-666-6785		860-667-6764		203-500-2983	alfred.montoya@va.gov	

Contact Role(s): **Legal Contact**

Name		Organization			Job Title	
Mr. Daniel T. Wood		Va CT Healthcare System			Gems Program Manager	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
555 Willard Avenue				Newington	CT	06111
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-666-6951	6952	860-666-6832		475-355-5029	Daniel.Wood2@VA.gov	

Contact Role(s): **Administrative Contact**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source	
CT0949073	NEWINGTON VA MEDICAL CENTER-BUILDING 2E	NTNC	335	F	SWP	
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
555 WILLARD AVE			1			
Towns Served: NEWINGTON						

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0949053	NEWINGTON VA MEDICAL CENTER-BUILDING 1	NTNC	110	F	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
555 WILLARD AVE				1			
Towns Served: NEWINGTON							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)							
Asbestos (1094)			1 routine (RT) per nine years				
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19						
Total Coliform (3100)			1 routine (RT) per quarter				
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete				
	10/1/16 - 12/31/16		Complete				
	1/1/17 - 3/31/17						
	4/1/17 - 6/30/17						
	7/1/17 - 9/30/17						
Lead And Copper (PBCU)			5 routine (RT) per six months				
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				
Select from Inventory of Active Sampling Points	7/1/16 - 12/31/16		Complete				
	1/1/17 - 6/30/17						
	7/1/17 - 12/31/17						
Physical Parameters (PPS)			1 routine (RT) per quarter				
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				
Select from Inventory of Active Sampling Points	1/1/17 - 3/31/17						
	4/1/17 - 6/30/17						
	7/1/17 - 9/30/17						
Physical Parameters (PPX)			1 routine (RT) per quarter				
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete				
	10/1/16 - 12/31/16		Complete				

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: TREATMENT PLANT (WSFID: 00700)							
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month				
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.3 MG/L	2				
Start Date: 12/1/2013	Compliance History:	Operating Limit	Monitoring	Compliance Status:			
	Monitoring Period	Compliance Status:	Compliance Status:				
	9/1/2016 - 9/30/2016		N				
	10/1/2016 - 10/31/2016		N				
	11/1/2016 - 11/30/2016		N				
	12/1/2016 - 12/31/2016		N				
	1/1/2017 - 1/31/2017						
	2/1/2017 - 2/28/2017						

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
---------------------------------	------------------------------	--------------------------	-----------------------------------	------------------------------	----------------------------------	-----------------	---------------------

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0949053	NEWINGTON VA MEDICAL CENTER-BUILDING 1	NTNC	110	F	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
555 WILLARD AVE				1			
Towns Served: NEWINGTON							

00600	DISTRIBUTION SYSTEM	1-305	BLDG#1 3RD FLOOR	A	Y	2			
		1-414B	BLDG#1 4TH FLOOR	A	Y	2			
		1-416B	1-416B	A	Y	2			
		1-509	BLDG#1 5TH FLOOR	A	Y	2			
		1S-166	BLDG #1 PO4/ZN/1FL	A	Y	2			Y
		1S-178	DISTRIBUTION SYSTEM	A	Y	2			
		1S-272	BLDG#1 2ND FLOOR	A	Y	2			
		4	DISTRIBUTION SYSTEM	A					
		DOWNSTREAM	WITHIN 5 SERVICE CON	A					
		UPSTREAM	WITHIN 5 SERVICE CON	A					
00700	TREATMENT PLANT	3	TREATMENT PLANT	A					
58542	INTERCONNECTION - (MDC)								

Certified Operator Information

Water System Facility: **TREATMENT PLANT (WSF ID: 00700)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
HARKINS, STUART A.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
WITTENZELLNER, ROBERT	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2018

Contact Information

Name		Organization			Job Title			
Mr. Alfred Montoya		Va CT Healthcare System			Assitant Director			
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
555 Willard Avenue						Newington	CT	06111
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-666-6785		860-667-6764		203-500-2983	alfred.montoya@va.gov			

Contact Role(s): **Legal Contact**

Name		Organization			Job Title			
Mr. Daniel T. Wood		Va CT Healthcare System			Gems Program Manager			
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
555 Willard Avenue						Newington	CT	06111
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-666-6951	6952	860-666-6832		475-355-5029	Daniel.Wood2@VA.gov			

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0949063	NEWINGTON VA MEDICAL CENTER-BUILDING 2C	NTNC	80	F	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
555 WILLARD AVE				1			
Towns Served: NEWINGTON							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)							
Asbestos (1094)		1 routine (RT) per nine years					
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19						
Total Coliform (3100)		1 routine (RT) per quarter					
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete				
	10/1/16 - 12/31/16		Complete				
	1/1/17 - 3/31/17						
	4/1/17 - 6/30/17						
	7/1/17 - 9/30/17						
Lead And Copper (PBCU)		5 routine (RT) per six months					
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				
Select from Inventory of Active Sampling Points	7/1/16 - 12/31/16		Complete				
	1/1/17 - 6/30/17						
	7/1/17 - 12/31/17						
Physical Parameters (PPS)		1 routine (RT) per quarter					
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				
Select from Inventory of Active Sampling Points	1/1/17 - 3/31/17						
	4/1/17 - 6/30/17						
	7/1/17 - 9/30/17						
Physical Parameters (PPX)		1 routine (RT) per quarter					
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete				
	10/1/16 - 12/31/16		Complete				

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: TREATMENT PLANT (WSFID: 00700)							
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.3 MG/L			2		
Start Date: 12/1/2013	Compliance History:	Operating Limit	Monitoring		Compliance Status:		
	Monitoring Period	Compliance Status:	Compliance Status:				
	9/1/2016 - 9/30/2016		N				
	10/1/2016 - 10/31/2016		N				
	11/1/2016 - 11/30/2016		N				
	12/1/2016 - 12/31/2016		N				
	1/1/2017 - 1/31/2017						
	2/1/2017 - 2/28/2017						

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2018	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0949063	NEWINGTON VA MEDICAL CENTER-BUILDING 2C	NTNC	80	F	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
555 WILLARD AVE				1			
Towns Served: NEWINGTON							

Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification		PN Certification	
			Required	Performed	Due to DPH	Received
Water Quality Parameters - Basic M&R Violation	7/1/15 - 12/31/15	3	6/27/2017		7/7/2017	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and		Stage 2	
					Coliform Rule	Copper Rule Tier	Asbestos	DBPR	
00600	DISTRIBUTION SYSTEM	2C-1132	DISTRIBUTION SYSTEM	A	Y				
		2C-1161	BLDG #2C PO4/ZN	A	Y	2		Y	
		2C-202	BLDG #2C 2ND FL/1	A	Y	2			
		2C-2106	BLDG 2C 2ND FL/3	A	Y	2			
		2C-2135	BLDG #2C 2ND FL/2	A	Y	2			
		2C-2136	DISTRIBUTION SYSTEM	A	Y				
		2C-3127	BLDG #2C 3RD FL	A	Y	2			
		4	DISTRIBUTION SYSTEM	A					
00700	TREATMENT PLANT	DOWNSTREAM	WITHIN 5 SERVICE CON	A					
		UPSTREAM	WITHIN 5 SERVICE CON	A					
00700	TREATMENT PLANT	3	TREATMENT PLANT	A					
58542	INTERCONNECTION - (MDC)								

Certified Operator Information

Water System Facility: **TREATMENT PLANT (WSF ID: 00700)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
HARKINS, STUART A.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
WITTENZELLNER, ROBERT	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2018

Contact Information

Name		Organization			Job Title			
Mr. Alfred Montoya		Va CT Healthcare System			Assitant Director			
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
555 Willard Avenue						Newington	CT	06111
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-666-6785		860-667-6764		203-500-2983	alfred.montoya@va.gov			
Contact Role(s): Legal Contact								

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
CT0949063	NEWINGTON VA MEDICAL CENTER-BUILDING 2C	NTNC	80	F	SWP			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
555 WILLARD AVE				1				
Towns Served: NEWINGTON								
Name			Organization			Job Title		
Mr. Daniel T. Wood			Va CT Healthcare System			Gems Program Manager		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
555 Willard Avenue						Newington	CT	06111
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-666-6951	6952	860-666-6832		475-355-5029	Daniel.Wood2@VA.gov			
Contact Role(s): Administrative Contact								

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule