

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0950011	NEW LONDON DEPT. OF PUBLIC UTILITIES	C	26,273	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			5,112	1,336	10	569	

Towns Served: NEW LONDON, WATERFORD

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/12 - 12/31/20		
<b>Total Coliform (3100)</b>	<b>30 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		
<b>Disinfectant Byproducts - TTHM &amp; HAA5 (DBP)</b>	<b>4 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
PEQUOT HOSE CO. (NLDPU002)	7/1/16 - 9/30/16	7/1-7/31	Complete
	10/1/16 - 12/31/16	10/1-10/31	Complete
	1/1/17 - 3/31/17	1/1-1/31	
	4/1/17 - 6/30/17	4/1-4/30	
FIRE HDQTS. BANK ST. (NLDPU003)	7/1/17 - 9/30/17	7/1-7/31	
	7/1/16 - 9/30/16	7/1-7/31	Complete
	10/1/16 - 12/31/16	10/1-10/31	Complete
	1/1/17 - 3/31/17	1/1-1/31	
CONN. COLLEGE (NLDPU004)	4/1/17 - 6/30/17	4/1-4/30	
	7/1/17 - 9/30/17	7/1-7/31	
	7/1/16 - 9/30/16	7/1-7/31	Complete
	10/1/16 - 12/31/16	10/1-10/31	Complete
WOW OCEAN BEACH (NLDPU050)	1/1/17 - 3/31/17	1/1-1/31	
	4/1/17 - 6/30/17	4/1-4/30	
	7/1/17 - 9/30/17	7/1-7/31	
	7/1/16 - 9/30/16	7/1-7/31	Complete
	10/1/16 - 12/31/16	10/1-10/31	Complete
	1/1/17 - 3/31/17	1/1-1/31	
	4/1/17 - 6/30/17	4/1-4/30	
	7/1/17 - 9/30/17	7/1-7/31	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0950011	NEW LONDON DEPT. OF PUBLIC UTILITIES	C	26,273	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			5,112	1,336	10	569	

Towns Served: NEW LONDON, WATERFORD

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

**Lead And Copper (PBCU) 20 routine (RT) per three years**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/15 - 12/31/17	6/1-9/30	
	1/1/18 - 12/31/20	6/1-9/30	

**Physical Parameters (PPS) 30 routine (RT) per month**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/17 - 1/31/17		
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

**Physical Parameters (PPX) 30 routine (RT) per month**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete

Water System Facility: **LAKE KONOMOC WTP ENTRY POINT (WSF ID: 00701)**

**Net Gross Alpha (4000) 1 routine (RT) per three years**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - LAKE KONOMOC TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

**Uranium (4006) 1 routine (RT) per three years**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - LAKE KONOMOC TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

**Combined Radium-226/228 (4010) 1 routine (RT) per three years**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - LAKE KONOMOC TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

**Inorganic Chemicals (IOCS) 1 routine (RT) per year**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - LAKE KONOMOC TP (3)	1/1/16 - 12/31/16		Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0950011	NEW LONDON DEPT. OF PUBLIC UTILITIES	C	26,273	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			5,112	1,336	10	569	

Towns Served: NEW LONDON, WATERFORD

### Monitoring Requirements

Water System Facility: LAKE KONOMOC WTP ENTRY POINT (WSF ID: 00701)

<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LAKE KONOMOC TP (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		
<b>Pesticides, Herbicides and PCBs-Phase II (SOC2)</b>	<b>2 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LAKE KONOMOC TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
<b>Pesticides, Herbicides and PCBs-Phase V (SOC5)</b>	<b>2 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LAKE KONOMOC TP (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LAKE KONOMOC TP (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Water System Facility: LAKE KONOMOC WATER TREATMENT PLANT (WSF ID: 199)

<b>Total Organic Carbon (2920)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CFE- LAKE KONOMOC TP (5)	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0950011	NEW LONDON DEPT. OF PUBLIC UTILITIES	C	26,273	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			5,112	1,336	10	569	

Towns Served: NEW LONDON, WATERFORD

### Monitoring Requirements

Water System Facility: LAKE KONOMOC RESERVOIR (WSF ID: 2162)

<b>Color (1905)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
LAKE KONOMOC RESERVOIR (1)	1/1/17 - 3/31/17				
	4/1/17 - 6/30/17				
	7/1/17 - 9/30/17				
<b>Total Alkalinity (1927)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
LAKE KONOMOC RESERVOIR (1)	8/1/16 - 8/31/16		Complete		
	9/1/16 - 9/30/16		Complete		
	10/1/16 - 10/31/16		Complete		
	11/1/16 - 11/30/16		Complete		
	12/1/16 - 12/31/16		Complete		
	1/1/17 - 1/31/17				
	2/1/17 - 2/28/17				
	3/1/17 - 3/31/17				
	4/1/17 - 4/30/17				
	5/1/17 - 5/31/17				
	6/1/17 - 6/30/17				
	7/1/17 - 7/31/17				
	8/1/17 - 8/31/17				
<b>Total Organic Carbon (2920)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
LAKE KONOMOC RESERVOIR (1)	8/1/16 - 8/31/16		Complete		
	9/1/16 - 9/30/16		Complete		
	10/1/16 - 10/31/16		Complete		
	11/1/16 - 11/30/16		Complete		
	12/1/16 - 12/31/16		Complete		
	1/1/17 - 1/31/17				
	2/1/17 - 2/28/17				
	3/1/17 - 3/31/17				
	4/1/17 - 4/30/17				
	5/1/17 - 5/31/17				
	6/1/17 - 6/30/17				
	7/1/17 - 7/31/17				
	8/1/17 - 8/31/17				
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
LAKE KONOMOC RESERVOIR (1)	7/1/16 - 9/30/16		Complete		
	10/1/16 - 12/31/16		Complete		
	1/1/17 - 3/31/17				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0950011	NEW LONDON DEPT. OF PUBLIC UTILITIES	C	26,273	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			5,112	1,336	10	569	

Towns Served: NEW LONDON, WATERFORD

## Monitoring Requirements

Water System Facility: LAKE KONOMOC RESERVOIR (WSF ID: 2162)

<b>Total Coliform (3100)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		
<b>LT2 - Cryptosporidium, Turbidity &amp; E. coli (LT2)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LAKE KONOMOC RESERVOIR (1)	10/1/16 - 10/31/16	10/16-10/20	
	11/1/16 - 11/30/16	11/13-11/17	
	12/1/16 - 12/31/16	12/11-12/15	
	1/1/17 - 1/31/17	1/15-1/19	
	2/1/17 - 2/28/17	2/19-2/23	
	3/1/17 - 3/31/17	3/19-3/23	
	4/1/17 - 4/30/17	4/16-4/20	
	5/1/17 - 5/31/17	5/21-5/25	
	6/1/17 - 6/30/17	6/18-6/22	
	7/1/17 - 7/31/17	7/16-7/20	
	8/1/17 - 8/31/17	8/20-8/24	
<b>Raw Water Physical Parameters (PHYR)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LAKE KONOMOC RESERVOIR (1)	7/1/16 - 9/30/16		Complete
	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete
<b>Surface Water Inorganic Chemicals (RIOC)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LAKE KONOMOC RESERVOIR (1)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		
<b>Surface Water Pesticides (RSOC)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LAKE KONOMOC RESERVOIR (1)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: LAKE KONOMOC WATER TREATMENT PLANT (WSFID: 199)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
<b>Start Date:</b> 10/1/2003	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	8/1/2016 - 8/31/2016	Y	Y

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0950011</b>	<b>NEW LONDON DEPT. OF PUBLIC UTILITIES</b>	C	26,273	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			5,112	1,336	10	569	

Towns Served: NEW LONDON, WATERFORD

## Water System Facility: LAKE KONOMOC WATER TREATMENT PLANT (WSFID: 199)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
<b>Start Date:</b> 10/1/2003		<b>Compliance History:</b>	<b>Monitoring Compliance Status:</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		9/1/2016 - 9/30/2016	Y
		10/1/2016 - 10/31/2016	N
		11/1/2016 - 11/30/2016	N
		12/1/2016 - 12/31/2016	
		1/1/2017 - 1/31/2017	

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
WATERSHED SURVEY REPORT	3/1/2017	
CROSS CONNECTION SURVEY REPORT	3/1/2017	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	3/31/2017	
SUBMIT CCR TO THE DEPARTMENT	6/30/2017	
SUBMIT CCR CERTIFICATION FORM	8/9/2017	
LT2 - SUBMIT BIN CLASSIFICATION	3/30/2019	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		NLDPU001	NLWPC	A	Y			
		NLDPU002	PEQUOT HOSE CO.	A	Y			Y
		NLDPU003	FIRE HDQTS. BANK ST.	A	Y			Y
		NLDPU004	CONN. COLLEGE	A	Y			Y
		NLDPU005	109 CRYSTAL AVE.	A	Y			
		NLDPU006	107 COLMAN ST.	A	Y			
		NLDPU007	LOMBARDI AUTO	A	Y			
		NLDPU008	L & M HOSPITAL	A	Y			
		NLDPU009	120 BROAD STREET	A	Y			
		NLDPU013	29 WEST ST.	A	Y	1		
		NLDPU014	41 WOODLAWN ROAD	A	Y	1		
		NLDPU015	298 CRYSTAL AVE.	A	Y	1		
		NLDPU016	552 OCEAN AVE.	A	Y	1		
		NLDPU017	46 SUMMIT AVE.	A	Y	1		
		NLDPU018	311 VAUXHALL ST. ALT	A	Y	1		
		NLDPU021	22 ADDISON ST.	A	Y	1		
		NLDPU022	150 ASHCRAFT RD.	A	Y	1		Y
		NLDPU023	34 CHAPEL DR.	A	Y	1		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0950011</b>	<b>NEW LONDON DEPT. OF PUBLIC UTILITIES</b>	<b>C</b>	26,273	<b>L</b>	<b>SW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			5,112	1,336	10	569	

Towns Served: NEW LONDON, WATERFORD

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
		NLDPU024	278 CRYSTAL AVE.	A	Y	1		
		NLDPU025	12 FINCH AVE.	A	Y	1		
		NLDPU026	83 THAMES ST.	A	Y	1		
		NLDPU028	20 FINCH AVE.	A	Y	1		
		NLDPU029	113 RIVERVIEW AVE.	A	Y	1		
		NLDPU030	366 VAUXHALL ST.	A	Y	1		
		NLDPU033	959 PEQUOT AVE.	A	Y	1		
		NLDPU034	17 THAMES ST.	A	Y	1		
		NLDPU035	88 VAUXHALL ST.	A	Y	1		
		NLDPU040	310 VAUXHALL ST.	A	Y	1		
		NLDPU041	200 LEDYARD ST.	A	Y	1		
		NLDPU042	95 THAMES ST.	A	Y	1		
		NLDPU043	273 OCEAN AVE.	A	Y	1		
		NLDPU044	123 VAUXHALL ST.	A	Y	1		
		NLDPU045	US COAST GUARD	A	Y	N		
		NLDPU050	WOW OCEAN BEACH	A				Y
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00701	LAKE KONOMOC WTP ENTRY POINT	3	EP - LAKE KONOMOC TP	A				
199	LAKE KONOMOC WATER TREATMENT PLANT	5	CFE- LAKE KONOMOC TP	A				
2162	LAKE KONOMOC RESERVOIR	1	LAKE KONOMOC RESERVO	A				
2163	BARNES RESERVOIR	1	RESERVOIR	A				
2164	BOGUE BROOK RESERVOIR	1	RESERVOIR	A				
2165	FAIRY LAKE RESERVOIR	1	RESERVOIR	A				
2166	BECKWITH POND	1	RESERVOIR	A				
2167	GREAT SWAMP DIVERSION	1	RESERVOIR	A				
2169	HUNTS BROOK RESERVOIR	1	RESERVOIR	A				
30065	GREAT SWAMP DIVERSION							
30070	LAKE KONOMOC INTAKE							
49682	WILLIAMS STREET PUMP STATION							
53892	LAKE KONOMOC WTP CLEARWELL							
53894	BECKWITH POND RAW WATER PUMP STATION							
53896	TREMONT STREET STORAGE TANK							

**NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.**

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0950011</b>	<b>NEW LONDON DEPT. OF PUBLIC UTILITIES</b>	<b>C</b>	26,273	<b>L</b>	<b>SW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			5,112	1,336	10	569	

Towns Served: NEW LONDON, WATERFORD

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule Tier	Stage 2 Asbestos DBPR
53898	MANATUCK HILL STORAGE TANK					
53900	GALLOWS LANE STORAGE TANK					
53902	LAKE KONOMOC WTP PUMP STATION					
53904	LAKE KONOMOC WTP RAW WATER PUMP STATION					
54140	GREAT SWAMP DIVERSION PUMP STATION					

## Certified Operator Information

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Facility Classification:</b> CLASS 2 DISTRIBUTION SYSTEM				<b>Certification Expiration</b>
Operator Name	Operator Type	Certification(s)		
VETTER, PETER	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	9/30/2018	
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2018	

**Water System Facility: LAKE KONOMOC WATER TREATMENT PLANT (WSF ID: 199)**

<b>Facility Classification:</b> CLASS 3 TREATMENT PLANT				<b>Certification Expiration</b>
Operator Name	Operator Type	Certification(s)		
DONBROSKY, STEVEN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	9/30/2017	
MCVICKER, JONATHAN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2017	
		WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2017	
SIGNORINO, KEVIN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2017	

## Contact Information

Name		Organization			Job Title		
<b>Mr. Thomas Londregan</b>		City of New London			City Attorney		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
38 Huntington Street					New London	CT	06320
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-447-3171							

**Contact Role(s): Legal Contact**

Name		Organization			Job Title		
<b>Mr. Joseph M. Lanzafame</b>		New London Public Utilities			Public Utilities Dir		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
City of New London		120 Broad Street			New London	CT	06320
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-373-1868		860-701-7693		860-447-5221	jlanzafame@ci.new-london.ct.us		

**Contact Role(s): Administrative Contact**

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0950011</b>	<b>NEW LONDON DEPT. OF PUBLIC UTILITIES</b>	<b>C</b>	26,273	<b>L</b>	<b>SW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			5,112	1,336	10	569	
Towns Served: NEW LONDON, WATERFORD							
Name			Organization		Job Title		
<b>Mr. Michael Passero</b>			City of New London		Mayor		
Mailing Address Line One			Mailing Address Line Two		City	State	Zip Code
181 State Street					New London	CT	06230
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-447-5201				860-625-7516	mpassero@ci.new-london.ct.us		
Contact Role(s): <b>Owner</b>							

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**