

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1430011</b>	<b>TORRINGTON WATER COMPANY</b>	<b>C</b>	37,915	<b>P</b>	<b>SW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			8,812	854		163	

Towns Served: HARWINTON, LITCHFIELD, NEW HARTFORD, TORRINGTON

### Monitoring Requirements

**Water System Facility: RAW SURFACE WATER BLENDED SAMPLE TAP (WSF ID: 00500)**

<b>Total Alkalinity (1927)</b>		<b>1 routine (RT) per month</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RAW SW BLENDED TAP (SP1)	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

<b>Total Organic Carbon (2920)</b>		<b>1 routine (RT) per month</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RAW SW BLENDED TAP (SP1)	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/12 - 12/31/20		

<b>Total Coliform (3100)</b>		<b>40 routine (RT) per month</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1430011</b>	<b>TORRINGTON WATER COMPANY</b>	<b>C</b>	37,915	<b>P</b>	<b>SW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			8,812	854		163	

Towns Served: HARWINTON, LITCHFIELD, NEW HARTFORD, TORRINGTON

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Total Coliform (3100)</b>		<b>40 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
	12/1/16 - 12/31/16		Complete	
	1/1/17 - 1/31/17			
	2/1/17 - 2/28/17			
	3/1/17 - 3/31/17			
	4/1/17 - 4/30/17			
	5/1/17 - 5/31/17			
	6/1/17 - 6/30/17			
	7/1/17 - 7/31/17			
	8/1/17 - 8/31/17			
<b>Disinfectant Byproducts - TTHM &amp; HAA5 (DBP)</b>		<b>6 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
CHAR HUNG. HOSP. (TWC007)	10/1/16 - 12/31/16	11/1-11/30	Complete	
	1/1/17 - 3/31/17	2/1-2/28		
	4/1/17 - 6/30/17	5/1-5/31		
	7/1/17 - 9/30/17	8/1-8/31		
NORTH RD, HRWTN (TWC038)	10/1/16 - 12/31/16	11/1-11/30	Complete	
	1/1/17 - 3/31/17	2/1-2/28		
	4/1/17 - 6/30/17	5/1-5/31		
	7/1/17 - 9/30/17	8/1-8/31		
ARBOR RIDGE (TWC059)	10/1/16 - 12/31/16	11/1-11/30	Complete	
	1/1/17 - 3/31/17	2/1-2/28		
	4/1/17 - 6/30/17	5/1-5/31		
	7/1/17 - 9/30/17	8/1-8/31		
30 PECK ROAD (TWC060)	10/1/16 - 12/31/16	11/1-11/30	Complete	
	1/1/17 - 3/31/17	2/1-2/28		
	4/1/17 - 6/30/17	5/1-5/31		
	7/1/17 - 9/30/17	8/1-8/31		
LAKERIDGE METER PIT (TWC080)	10/1/16 - 12/31/16	11/1-11/30	Complete	
	1/1/17 - 3/31/17	2/1-2/28		
	4/1/17 - 6/30/17	5/1-5/31		
	7/1/17 - 9/30/17	8/1-8/31		
THOMPSON METERING HOUSE (TWC082)	10/1/16 - 12/31/16	11/1-11/30	Complete	
	1/1/17 - 3/31/17	2/1-2/28		
	4/1/17 - 6/30/17	5/1-5/31		
	7/1/17 - 9/30/17	8/1-8/31		
<b>Disinfectant Byproducts - TTHM &amp; HAA5 (DBP)</b>		<b>5 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
CHAR HUNG. HOSP. (TWC007)	7/1/16 - 9/30/16	8/1-8/31	Complete	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1430011	TORRINGTON WATER COMPANY	C	37,915	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			8,812	854		163	

Towns Served: HARWINTON, LITCHFIELD, NEW HARTFORD, TORRINGTON

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Disinfectant Byproducts - TTHM &amp; HAA5 (DBP)</b>		<b>5 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
NORTH RD, HRWTN (TWC038)	7/1/16 - 9/30/16	8/1-8/31	Complete
ARBOR RIDGE (TWC059)	7/1/16 - 9/30/16	8/1-8/31	Complete
30 PECK ROAD (TWC060)	7/1/16 - 9/30/16	8/1-8/31	Complete
LAKERIDGE METER PIT (TWC080)	7/1/16 - 9/30/16	8/1-8/31	Complete

<b>Lead And Copper (PBCU)</b>		<b>30 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/15 - 12/31/17	6/1-9/30	
	1/1/18 - 12/31/20	6/1-9/30	

<b>Physical Parameters (PPS)</b>		<b>40 routine (RT) per month</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/17 - 1/31/17		
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

<b>Physical Parameters (PPX)</b>		<b>40 routine (RT) per month</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete

Water System Facility: **TORRINGTON FILTRATION PLANT -ENTRY POINT (WSF ID: 00700)**

<b>Net Gross Alpha (4000)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WTPLANT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

<b>Uranium (4006)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WTPLANT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

<b>Combined Radium-226/228 (4010)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1430011</b>	<b>TORRINGTON WATER COMPANY</b>	C	37,915	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			8,812	854		163	

Towns Served: HARWINTON, LITCHFIELD, NEW HARTFORD, TORRINGTON

### Monitoring Requirements

Water System Facility: **TORRINGTON FILTRATION PLANT -ENTRY POINT (WSF ID: 00700)**

**Combined Radium-226/228 (4010) 1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WTPLANT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

**Inorganic Chemicals (IOCS) 1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WTPLANT (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

**Nitrate And Nitrite (NOX) 1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WTPLANT (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

**Pesticides, Herbicides and PCBs - Phase II & V (SOCS) 2 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WTPLANT (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

**Organic Chemicals (VOCS) 1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WTPLANT (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Water System Facility: **ALLEN DAM RESERVOIR (WSF ID: 30090)**

**Color (1905) 1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ALLEN DAM RES INTAKE (SP1)	1/1/17 - 3/31/17		
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

**Total Coliform (3100) 1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ALLEN DAM RES INTAKE (SP1)	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete
	1/1/17 - 3/31/17		Complete
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

**LT2 - Cryptosporidium, Turbidity & E. coli (LT2) 1 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1430011</b>	<b>TORRINGTON WATER COMPANY</b>	<b>C</b>	37,915	<b>P</b>	<b>SW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			8,812	854		163	

Towns Served: HARWINTON, LITCHFIELD, NEW HARTFORD, TORRINGTON

### Monitoring Requirements

Water System Facility: **ALLEN DAM RESERVOIR (WSF ID: 30090)**

<b>LT2 - Cryptosporidium, Turbidity &amp; E. coli (LT2)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ALLEN DAM RES INTAKE (SP1)	10/1/16 - 10/31/16	10/10-10/14	
	11/1/16 - 11/30/16	11/17-11/21	
	12/1/16 - 12/31/16	12/12-12/16	
	1/1/17 - 1/31/17	1/9-1/13	
	2/1/17 - 2/28/17	2/12-2/16	
	3/1/17 - 3/31/17	3/12-3/16	
	4/1/17 - 4/30/17	4/10-4/14	
	5/1/17 - 5/31/17	5/8-5/12	
	6/1/17 - 6/30/17	6/12-6/16	
	7/1/17 - 7/31/17	7/10-7/14	
	8/1/17 - 8/31/17	8/6-8/10	

<b>Raw Water Physical Parameters (PHYR)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ALLEN DAM RES INTAKE (SP1)	7/1/16 - 9/30/16		Complete
	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete

<b>Surface Water Inorganic Chemicals (RIOCI)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ALLEN DAM RES INTAKE (SP1)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

<b>Surface Water Pesticides (RSOC)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ALLEN DAM RES INTAKE (SP1)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Water System Facility: **REUBEN HART RES (WSF ID: 30091)**

<b>Color (1905)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
R HART RES INTAKE (SP1)	1/1/17 - 3/31/17		
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

<b>Total Coliform (3100)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
R HART RES INTAKE (SP1)	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete
	1/1/17 - 3/31/17		Complete
	4/1/17 - 6/30/17		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1430011</b>	<b>TORRINGTON WATER COMPANY</b>	<b>C</b>	37,915	<b>P</b>	<b>SW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			8,812	854		163	

Towns Served: HARWINTON, LITCHFIELD, NEW HARTFORD, TORRINGTON

### Monitoring Requirements

Water System Facility: **REUBEN HART RES (WSF ID: 30091)**

<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	7/1/17 - 9/30/17		

<b>LT2 - Cryptosporidium, Turbidity &amp; E. coli (LT2)</b>		<b>1 routine (RT) per month</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
R HART RES INTAKE (SP1)	10/1/16 - 10/31/16	10/10-10/14	
	11/1/16 - 11/30/16	11/17-11/21	
	12/1/16 - 12/31/16	12/12-12/16	
	1/1/17 - 1/31/17	1/9-1/13	
	2/1/17 - 2/28/17	2/12-2/16	
	3/1/17 - 3/31/17	3/12-3/16	
	4/1/17 - 4/30/17	4/10-4/14	
	5/1/17 - 5/31/17	5/8-5/12	
	6/1/17 - 6/30/17	6/12-6/16	
	7/1/17 - 7/31/17	7/10-7/14	
	8/1/17 - 8/31/17	8/6-8/10	

<b>Raw Water Physical Parameters (PHYR)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
R HART RES INTAKE (SP1)	7/1/16 - 9/30/16		Complete
	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete

<b>Surface Water Inorganic Chemicals (RIOCI)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
R HART RES INTAKE (SP1)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

<b>Surface Water Pesticides (RSOC)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
R HART RES INTAKE (SP1)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Water System Facility: **TORRINGTON FILTRATION PLANT (WSF ID: 323)**

<b>Total Organic Carbon (2920)</b>		<b>1 routine (RT) per month</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - TORRINGTON TP (SP5)	8/1/16 - 8/31/16		Complete
	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1430011</b>	<b>TORRINGTON WATER COMPANY</b>	C	37,915	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			8,812	854		163	

Towns Served: HARWINTON, LITCHFIELD, NEW HARTFORD, TORRINGTON

## Monitoring Requirements

Water System Facility: **TORRINGTON FILTRATION PLANT (WSF ID: 323)**

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **TORRINGTON FILTRATION PLANT -ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily
<b>Start Date:</b> 1/1/2004			
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	8/1/2016 - 8/31/2016		N
	9/1/2016 - 9/30/2016		N
	10/1/2016 - 10/31/2016		N
	11/1/2016 - 11/30/2016		N
	12/1/2016 - 12/31/2016		
	1/1/2017 - 1/31/2017		

Water System Facility: **TORRINGTON FILTRATION PLANT (WSFID: 323)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
<b>Start Date:</b> 1/1/2004			
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	8/1/2016 - 8/31/2016	Y	Y
	9/1/2016 - 9/30/2016	Y	Y
	10/1/2016 - 10/31/2016		N
	11/1/2016 - 11/30/2016		N
	12/1/2016 - 12/31/2016		
	1/1/2017 - 1/31/2017		

## Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2014	
WATERSHED SURVEY REPORT	3/1/2017	
SUBMIT CCR TO THE DEPARTMENT	6/30/2017	
SUBMIT CCR CERTIFICATION FORM	8/9/2017	
CROSS CONNECTION SURVEY REPORT	3/1/2018	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1430011</b>	<b>TORRINGTON WATER COMPANY</b>	<b>C</b>	37,915	<b>P</b>	<b>SW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			8,812	854		163	

Towns Served: HARWINTON, LITCHFIELD, NEW HARTFORD, TORRINGTON

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
LT2 - SUBMIT BIN CLASSIFICATION	3/30/2019	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
00500	RAW SURFACE WATER BLENDED SAMPLE TAP	SP1	RAW SW BLENDED TAP	A				
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		TWC001	1970 NORFOLK RD	A	Y	3		
		TWC002	SQUIRE HILL P.S.	A	Y			
		TWC003	WINTHROP ST. P.S.	A	Y			
		TWC004	TORR. WEST ST P.S.	A	Y			
		TWC005	WEST PEARL TANK	A	Y			
		TWC006	HIGHFIELD DRIVE	A	Y			
		TWC007	CHAR HUNG. HOSP.	A	Y			Y
		TWC008	GREENBRIAR P.S.	A	Y			
		TWC009	59 ELMIRA	A		1		
		TWC010	33 SYCAMORE DR	A		1		
		TWC011	73 BRIGHTWOOD AVE	A		2		
		TWC012	111 SUNCREST CT	A		1		
		TWC013	1318 TORR. ST.	A		3		
		TWC015	517 PROSPECT ST	A		3		
		TWC016	20 LAWRENCE LANE	A		1		
		TWC017	55 BLINKOFF CT	A		1		
		TWC018	88 N CHAPEL ST	A		3		
		TWC019	193 LINCOLN AVE	A		3		
		TWC020	164 FUNSTON AVE	A		3		
		TWC021	126 MILL LANE	A		1		
		TWC022	91 VIEW ST	A		3		
		TWC023	57 DOROTHY DR	A		3		
		TWC024	130 SPRING ST	I		3		
		TWC025	76 ELMIRA	A		3		
		TWC026	107 DARTMOUTH ST	A		3		
		TWC027	109 COOLIDGE AVE	A		3		
		TWC028	149 BLAKE ST	A		3		
		TWC029	959 LITCHFIELD ST	I		3		
		TWC030	281 WYOMING AVE	A		3		
		TWC031	196 BRADFORD RD	A		3		
		TWC032	76 HIGH ST	A		3		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1430011</b>	<b>TORRINGTON WATER COMPANY</b>	<b>C</b>	37,915	<b>P</b>	<b>SW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			8,812	854		163	

Towns Served: HARWINTON, LITCHFIELD, NEW HARTFORD, TORRINGTON

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
		TWC033	129 MAPLEWOOD AVE	A		3		
		TWC034	7 WINSTED RD	A		3		
		TWC035	NORTH RD	A	Y			
		TWC037	25 COUNTRY CLUB RD	A		1		
		TWC038	NORTH RD, HRWTN	A	Y			Y
		TWC039	RTE 4 @ SMITH LANE	A	Y			
		TWC040	305 OAK AVE	A		3		
		TWC041	150 ALVORD PARK RD	A		3		
		TWC042	255 ROBERTS ST	A		3		
		TWC044	48 LIMESTONE DR.	A	Y			
		TWC045	197 RIVERSIDE AVE	A		3		
		TWC046	154 CENTRAL AVE	A		3		
		TWC047	220 HEIGHTS DRIVE	A		1		
		TWC048	523 TORR W. UNIT 34	I		1		
		TWC049	48 FUNSTON AVE	I		3		
		TWC050	59 COUNTY LINE RD	A		3		
		TWC051	185 SPRING ST	A		3		
		TWC052	490 LITCHFIELD ST	A		3		
		TWC053	117 LIMESTONE DR	A		3		
		TWC054	727 TORR ST	A		1		
		TWC055	11 MILICI DRIVE	A		3		
		TWC056	116 DAWES AVE	A		3		
		TWC057	302 VILLAGE DRIVE	A	Y	1		
		TWC058	77 DARTMOUTH STREET	A	Y	3		
		TWC059	ARBOR RIDGE	A				Y
		TWC060	30 PECK ROAD	A				Y
		TWC061	BURRVILLE STP	A	Y			
		TWC062	LAKERIDGE OFFICE	A	Y			
		TWC063	137 WINSTED RD	A		2		
		TWC064	1229 WINSTED RD 118	I		2		
		TWC065	1229 WINSTED RD 32	I		2		
		TWC066	1229 WINSTED RD 30	I		2		
		TWC067	1229 WINSTED RD 209	A		2		
		TWC068	1229 WINSTED RD 47	A		2		
		TWC069	212 WINSTED RD	A		2		
		TWC070	1229 WINSTED RD 10	A		2		
		TWC071	1275 WINSTED RD 536	A		2		
		TWC072	1275 WINSTED RD 426	A		2		
		TWC073	1275 WINSTED RD 206	A		2		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1430011</b>	<b>TORRINGTON WATER COMPANY</b>	C	37,915	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			8,812	854		163	

Towns Served: HARWINTON, LITCHFIELD, NEW HARTFORD, TORRINGTON

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
		TWC074	1275 WINSTED RD 422	A		2		
		TWC075	1275 WINTSED RD 639	A		2		
		TWC076	PATCO MOBIL	A	Y	N		
		TWC078	BURRVILLE PACKAGE ST	I	Y			
		TWC079	1036 EAST MAIN ST	A	Y	1		
		TWC080	LAKERIDGE METER PIT	A	Y			Y
		TWC082	THOMPSON METERING HO	A				Y
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	TORRINGTON FILTRATION PLANT -ENTRY POINT	3	ENTRY POINT-WTPLANT	A				
2247	REUBEN HART RESERVOIR	1	RESERVOIR	A				
2248	ALLEN DAM RESERVOIR	1	RESERVOIR	A				
2249	NORTH POND	1	RESERVOIR	A				
2250	WHIST POND	1	RESERVOIR	A				
2253	NICKEL MINE BROOK DIVERSION	1	RESERVOIR	A				
30090	ALLEN DAM RESERVOIR	SP1	ALLEN DAM RES INTAKE	A				
30091	REUBEN HART RES	SP1	R HART RES INTAKE	A				
323	TORRINGTON FILTRATION PLANT	SP5	EP - TORRINGTON TP	A				
45367	WEST TORRINGTON TANK							
45369	LITCHFIELD STREET TANK							
45371	TORRINGFORD WEST STREET TANK							
45373	WEST PEARL ROAD TANK							
45375	HIGHLAND AVENUE TANK							
45377	SOAPSTONE HILL TANK							
49315	GREENBRIAR TANK							
49317	SQUIRE HILL TANK 1							
49319	SQUIRE HILL TANK 2							
49321	WINTHROP ST PUMP STATION							
49323	TORRINGFORD WEST ST PUMP STATION							
49327	GREENBRIAR PUMP STATION							
49329	SQUIRE HILL PUMP STATION							
54546	WESTSIDE HIGH PUMP STATION							

### Certified Operator Information

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1430011</b>	<b>TORRINGTON WATER COMPANY</b>	<b>C</b>	37,915	<b>P</b>	<b>SW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			8,812	854		163	

Towns Served: HARWINTON, LITCHFIELD, NEW HARTFORD, TORRINGTON

## Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: CLASS 2 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
CERRUTO, SR., STEVEN	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019

Water System Facility: **TORRINGTON FILTRATION PLANT (WSF ID: 323)**

Facility Classification: CLASS 3 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
DERWITSCH, JACOB J.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2017
CERRUTO, SR., STEVEN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2019
ROMA, MICHAEL	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2017

## Contact Information

Name		Organization			Job Title			
<b>Ms. Susan M. Suhanovsky</b>		Torrington Water Company			President			
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
277 Norfolk Road			P.O. Box 867			Torrington	CT	06790
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-489-4149		860-496-7889		860-480-4650	twcwater@aim.com			

Contact Role(s): **Administrative Contact, Legal Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**