

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1480011	WALLINGFORD WATER DEPARTMENT	C	37,267	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			10,200				

Towns Served: NORTH HAVEN, WALLINGFORD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/12 - 12/31/20		
Total Coliform (3100)	40 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		
Disinfectant Byproducts - TTHM & HAA5 (DBP)	4 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
377 S CHERRY ST (WWD0001)	7/1/16 - 9/30/16	9/1-9/7	Complete
	10/1/16 - 12/31/16	12/1-12/7	Complete
	1/1/17 - 3/31/17	3/1-3/7	
	4/1/17 - 6/30/17	6/1-6/7	
5 STERLING DRIVE (WWD0057)	7/1/17 - 9/30/17	9/1-9/7	
	7/1/16 - 9/30/16	9/1-9/7	Complete
	10/1/16 - 12/31/16	12/1-12/7	Complete
	1/1/17 - 3/31/17	3/1-3/7	
CHIMNEY HILL BLEEDER (WWD0058)	4/1/17 - 6/30/17	6/1-6/7	
	7/1/17 - 9/30/17	9/1-9/7	
	7/1/16 - 9/30/16	9/1-9/7	Complete
	10/1/16 - 12/31/16	12/1-12/7	Complete
MCGUIRE COURT (WWD0059)	1/1/17 - 3/31/17	3/1-3/7	
	4/1/17 - 6/30/17	6/1-6/7	
	7/1/17 - 9/30/17	9/1-9/7	
	7/1/16 - 9/30/16	9/1-9/7	Complete
	10/1/16 - 12/31/16	12/1-12/7	Complete
	1/1/17 - 3/31/17	3/1-3/7	
	4/1/17 - 6/30/17	6/1-6/7	
	7/1/17 - 9/30/17	9/1-9/7	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1480011	WALLINGFORD WATER DEPARTMENT	C	37,267	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			10,200				

Towns Served: NORTH HAVEN, WALLINGFORD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Lead And Copper (PBCU) 30 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/14 - 12/31/16	6/1-9/30	Complete
	1/1/17 - 12/31/19	6/1-9/30	
	1/1/20 - 12/31/22	6/1-9/30	

Physical Parameters (PPS) 40 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Physical Parameters (PPX) 40 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete

Water System Facility: PISTAPAUG POND WTP ENTRY POINT (WSF ID: 00700)

Net Gross Alpha (4000) 1 routine (RT) per nine years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/08 - 12/31/16		Complete
	1/1/17 - 12/31/25		

Uranium (4006) 1 routine (RT) per nine years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/08 - 12/31/16		Complete
	1/1/17 - 12/31/25		

Combined Radium-226/228 (4010) 1 routine (RT) per nine years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/08 - 12/31/16		Complete
	1/1/17 - 12/31/25		

Inorganic Chemicals (IOCS) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1480011	WALLINGFORD WATER DEPARTMENT	C	37,267	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			10,200				

Towns Served: NORTH HAVEN, WALLINGFORD

Monitoring Requirements

Water System Facility: PISTAPaug POND WTP ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)		1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/16 - 12/31/16		Complete	
	1/1/17 - 12/31/17			
	1/1/18 - 12/31/18			
Pesticides, Herbicides and PCBs-Phase II (SOC2)		2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete	
	1/1/17 - 12/31/19			
	1/1/20 - 12/31/22			
Pesticides, Herbicides and PCBs-Phase V (SOC5)		2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/14 - 12/31/16		Complete	
	1/1/17 - 12/31/19			
	1/1/20 - 12/31/22			
Organic Chemicals (VOCS)		1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/16 - 12/31/16		Complete	
	1/1/17 - 12/31/17			
	1/1/18 - 12/31/18			

Water System Facility: OAK STREET WELLS #2 & #3 ENTRY POINT (WSF ID: 00701)

Net Gross Alpha (4000)		1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP-OAK STREET 2 & 3 (3)	1/1/08 - 12/31/16		Complete	
	1/1/17 - 12/31/25			
Uranium (4006)		1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP-OAK STREET 2 & 3 (3)	1/1/08 - 12/31/16		Complete	
	1/1/17 - 12/31/25			
Combined Radium-226/228 (4010)		1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP-OAK STREET 2 & 3 (3)	1/1/08 - 12/31/16		Complete	
	1/1/17 - 12/31/25			
Inorganic Chemicals (IOCS)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP-OAK STREET 2 & 3 (3)	1/1/16 - 12/31/18			
	1/1/19 - 12/31/21			
Nitrate And Nitrite (NOX)		1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP-OAK STREET 2 & 3 (3)	1/1/16 - 12/31/16		Complete	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1480011	WALLINGFORD WATER DEPARTMENT	C	37,267	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			10,200				

Towns Served: NORTH HAVEN, WALLINGFORD

Monitoring Requirements

Water System Facility: OAK STREET WELLS #2 & #3 ENTRY POINT (WSF ID: 00701)

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		
Pesticides, Herbicides and PCBs-Phase II (SOC2)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-OAK STREET 2 & 3 (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Pesticides, Herbicides and PCBs-Phase V (SOC5)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-OAK STREET 2 & 3 (3)	1/1/14 - 12/31/16		Complete
	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-OAK STREET 2 & 3 (3)	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete
	1/1/17 - 3/31/17		
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

Water System Facility: RIDGELAND WELLFIELD - WELL#1 ENTRY POINT (WSF ID: 00702)

Net Gross Alpha (4000)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-RIDGELAND WELL 1 (3)	1/1/08 - 12/31/16		Complete
	1/1/17 - 12/31/25		
Uranium (4006)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-RIDGELAND WELL 1 (3)	1/1/08 - 12/31/16		Complete
	1/1/17 - 12/31/25		
Combined Radium-226/228 (4010)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-RIDGELAND WELL 1 (3)	1/1/08 - 12/31/16		Complete
	1/1/17 - 12/31/25		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-RIDGELAND WELL 1 (3)	1/1/16 - 12/31/18		
	1/1/19 - 12/31/21		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1480011	WALLINGFORD WATER DEPARTMENT	C	37,267	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			10,200				

Towns Served: NORTH HAVEN, WALLINGFORD

Monitoring Requirements

Water System Facility: RIDGELAND WELLFIELD - WELL#1 ENTRY POINT (WSF ID: 00702)

Nitrate And Nitrite (NOX) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-RIDGELAND WELL 1 (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) 1 (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-RIDGELAND WELL 1 (3)	1/1/14 - 12/31/16	1/1-12/31	Waiver

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-RIDGELAND WELL 1 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Organic Chemicals (VOCS) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-RIDGELAND WELL 1 (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Water System Facility: OAK STREET WELL #2 (WSF ID: 1390)

E. Coli (3014) 1 triggered (TG) per period

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
OAK STREET WELL #2 (2)	8/24/16 - 8/29/16		
	8/31/16 - 9/5/16		Complete

E. Coli (3014) 1 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
OAK STREET WELL #2 (2)	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		
	12/1/16 - 12/31/16		
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Water System Facility: OAK STREET WELL #3 (WSF ID: 1391)

E. Coli (3014) 1 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
OAK STREET WELL #3 (2)	9/1/16 - 9/30/16		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1480011	WALLINGFORD WATER DEPARTMENT	C	37,267	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			10,200				

Towns Served: NORTH HAVEN, WALLINGFORD

Monitoring Requirements

Water System Facility: OAK STREET WELL #3 (WSF ID: 1391)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	10/1/16 - 10/31/16		
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Out of Service
	1/1/17 - 1/31/17		
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Water System Facility: WELL #1 (WSF ID: 1392)

E. Coli (3014)	1 triggered (TG) per period		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #1 (2)	8/24/16 - 8/29/16		
	8/31/16 - 9/5/16		Complete

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #1 (2)	9/1/16 - 9/30/16		Complete
	10/1/16 - 10/31/16		Complete
	11/1/16 - 11/30/16		Complete
	12/1/16 - 12/31/16		Complete
	1/1/17 - 1/31/17		Complete
	2/1/17 - 2/28/17		
	3/1/17 - 3/31/17		
	4/1/17 - 4/30/17		
	5/1/17 - 5/31/17		
	6/1/17 - 6/30/17		
	7/1/17 - 7/31/17		
	8/1/17 - 8/31/17		

Water System Facility: PISTAPAUG POND (WSF ID: 2273)

Color (1905)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
PISTAPAUG POND (1)	1/1/17 - 3/31/17		
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

Total Alkalinity (1927)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1480011	WALLINGFORD WATER DEPARTMENT	C	37,267	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			10,200				

Towns Served: NORTH HAVEN, WALLINGFORD

Monitoring Requirements

Water System Facility: **PISTAPAUG POND (WSF ID: 2273)**

Total Alkalinity (1927)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
PISTAPAUG POND (1)	7/1/16 - 9/30/16		Complete		
	10/1/16 - 12/31/16		Complete		
	1/1/17 - 3/31/17		Complete		
	4/1/17 - 6/30/17				
	7/1/17 - 9/30/17				
Total Organic Carbon (2920)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
PISTAPAUG POND (1)	7/1/16 - 9/30/16		Complete		
	10/1/16 - 12/31/16		Complete		
	1/1/17 - 3/31/17		Complete		
	4/1/17 - 6/30/17				
	7/1/17 - 9/30/17				
Total Coliform (3100)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
PISTAPAUG POND (1)	7/1/16 - 9/30/16		Complete		
	10/1/16 - 12/31/16		Complete		
	1/1/17 - 3/31/17				
	4/1/17 - 6/30/17				
	7/1/17 - 9/30/17				
LT2 - Cryptosporidium, Turbidity & E. coli (LT2)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
PISTAPAUG POND (1)	10/1/16 - 10/31/16				
	11/1/16 - 11/30/16				
	12/1/16 - 12/31/16				
	1/1/17 - 1/31/17		Complete		
	2/1/17 - 2/28/17				
	3/1/17 - 3/31/17				
	4/1/17 - 4/30/17				
	5/1/17 - 5/31/17				
	6/1/17 - 6/30/17				
	7/1/17 - 7/31/17				
8/1/17 - 8/31/17					
Raw Water Physical Parameters (PHYR)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
PISTAPAUG POND (1)	7/1/16 - 9/30/16		Complete		
	7/1/16 - 9/30/16		Complete		
	10/1/16 - 12/31/16		Complete		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1480011	WALLINGFORD WATER DEPARTMENT	C	37,267	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			10,200				

Towns Served: NORTH HAVEN, WALLINGFORD

Monitoring Requirements

Water System Facility: **PISTAPPAUG POND (WSF ID: 2273)**

Surface Water Inorganic Chemicals (RIOCI) **1 routine (RT) per year**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
PISTAPPAUG POND (1)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Surface Water Pesticides (RSOC) **1 routine (RT) per year**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
PISTAPPAUG POND (1)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Water System Facility: **PISTAPPAUG POND WATER TREATMENT PLANT (WSF ID: 289)**

Total Organic Carbon (2920) **1 routine (RT) per quarter**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - PISTAPPAUG TP (5)	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete
	1/1/17 - 3/31/17		Complete
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **PISTAPPAUG POND WTP ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 7/1/2003		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		9/1/2016 - 9/30/2016	N
		10/1/2016 - 10/31/2016	N
		11/1/2016 - 11/30/2016	N
		12/1/2016 - 12/31/2016	N
		1/1/2017 - 1/31/2017	
		2/1/2017 - 2/28/2017	

Water System Facility: **OAK STREET WELLS #2 & #3 ENTRY POINT (WSFID: 00701)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
Start Date: 7/1/2003		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		9/1/2016 - 9/30/2016	N
		10/1/2016 - 10/31/2016	N
		11/1/2016 - 11/30/2016	N
		12/1/2016 - 12/31/2016	N

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1480011	WALLINGFORD WATER DEPARTMENT	C	37,267	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			10,200				
Towns Served: NORTH HAVEN, WALLINGFORD							
Water System Facility: OAK STREET WELLS #2 & #3 ENTRY POINT (WSFID: 00701)							
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L			Daily		
Start Date: 7/1/2003		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		1/1/2017 - 1/31/2017					
		2/1/2017 - 2/28/2017					
Water System Facility: RIDGELAND WELLFIELD - WELL#1 ENTRY POINT (WSFID: 00702)							
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L			Daily		
Start Date: 7/1/2003		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		9/1/2016 - 9/30/2016			N		
		10/1/2016 - 10/31/2016			N		
		11/1/2016 - 11/30/2016			N		
		12/1/2016 - 12/31/2016			N		
		1/1/2017 - 1/31/2017					
		2/1/2017 - 2/28/2017					
Water System Facility: BARNES CHLORINATION ST ENTRY POINT (WSFID: 00703)							
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L			Daily		
Start Date: 1/1/2002		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		9/1/2016 - 9/30/2016			N		
		10/1/2016 - 10/31/2016			N		
		11/1/2016 - 11/30/2016			N		
		12/1/2016 - 12/31/2016			N		
		1/1/2017 - 1/31/2017					
		2/1/2017 - 2/28/2017					
Water System Facility: PISTAPaug POND WATER TREATMENT PLANT (WSFID: 289)							
Analyte	Monitoring Requirement (Summary Type)	Operating Limit			Samples Req/Month		
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU			186		
Start Date: 1/1/2002		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		9/1/2016 - 9/30/2016		Y	Y		
		10/1/2016 - 10/31/2016		Y	Y		
		11/1/2016 - 11/30/2016		Y	Y		
		12/1/2016 - 12/31/2016		Y	Y		
		1/1/2017 - 1/31/2017					
		2/1/2017 - 2/28/2017					

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1480011	WALLINGFORD WATER DEPARTMENT	C	37,267	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			10,200				

Towns Served: NORTH HAVEN, WALLINGFORD

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
CROSS CONNECTION SURVEY REPORT	3/1/2017	
WATERSHED SURVEY REPORT	3/1/2017	
SUBMIT CCR TO THE DEPARTMENT	6/30/2017	
SUBMIT CCR CERTIFICATION FORM	8/9/2017	
LT2 - SUBMIT BIN CLASSIFICATION	3/30/2019	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		WWD0001	377 S CHERRY ST	A	Y			Y
		WWD0002	134 S TURNPIKE RD	A	Y			
		WWD0002A	129 S. TURNPIKE ROAD	A	Y			
		WWD0003	60 GAYLORD FARMS	A	Y			
		WWD0004	60 PARKER FARMS RD	A	Y			
		WWD0005	200 HIGHLAND AVE	A	Y			
		WWD0006	508 MAIN STREET, YAL	A	Y			
		WWD0007	42 N PLAINS IND RD	A	Y			
		WWD0008	600 NORTHROP RD	A	Y			
		WWD0009	225 POND HILL RD	A	Y			
		WWD0010	636 BARNES RD	A	Y			
		WWD0011	HIGHLAND SAMP STA	A	Y			
		WWD0012	CL HOUSE SAMP STA	I	Y			
		WWD0012A	PRV VAULT SAMP STA	A	Y			
		WWD0013	1 ASHLEY LANE	A				
		WWD0014	141 HOPE HILL RD	A				
		WWD0015	1194 N COLONY RD	A				
		WWD0016	1 BERNADETTE LN	A		1		
		WWD0017	83 BRENTWOOD DR	A		1		
		WWD0018	254 BRENTWOOD DR	A		1		
		WWD0019	17 BRIARWOOD LN	A		1		
		WWD0020	15 BUTTONWOOD CIR	A		1		
		WWD0021	29 BUTTONWOOD CIR	A		1		
		WWD0022	9 CASSELLA DR	A		1		
		WWD0023	15 CASSELLA DR	A		1		
		WWD0024	809 CLINTONVILLE RD	A		1		
		WWD0025	108 COLONIAL HILL RD	A		1		
		WWD0026	4 COUNTRY WAY	A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1480011	WALLINGFORD WATER DEPARTMENT	C	37,267	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			10,200				

Towns Served: NORTH HAVEN, WALLINGFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
		WWD0027	18 COUNTRY WAY	A		1		
		WWD0028	1038 E CENTER ST	A		1		
		WWD0029	5 HAYLEDGE COURT	A		1		
		WWD0030	24 MAPLEVIEW RD	A		1		
		WWD0031	18 MELLOR DR	A		1		
		WWD0032	36 MELLOR DR	A		1		
		WWD0033	5 NOD BROOK RD	A		3		
		WWD0034	31 NOD BROOK RD	A		1		
		WWD0035	46 NOD BROOK RD	A		1		
		WWD0036	742 NORTH FARMS RD	A		1		
		WWD0037	161 PARKER FARMS RD	A		1		
		WWD0038	5 PARTRIDGE RUN	A		1		
		WWD0039	40 SAW MILL DR	A		3		
		WWD0040	70 SAW MILL DR	A		1		
		WWD0041	80 SAW MILL DR	A		1		
		WWD0042	85 SAW MILL DR	A		1		
		WWD0043	41 STAFFORDSHIRE COM	A		1		
		WWD0044	112 SUMMERHILL DR	A		1		
		WWD0045	21 TWIN OAK FARM RD	A		1		
		WWD0046	5 WOODS EDGE CIR	A		1		
		WWD0047	5 KIRTLAND COURT	A				
		WWD0048	35 STILLWOOD RD	A				
		WWD0050	519 MAIN ST, YALES	A	Y			
		WWD0051	50 N PLAINS IND RD	A	Y			
		WWD0052	500 MAIN ST, YALES	I	Y			
		WWD0053	61 SAW MILL DR	A		1		
		WWD0054	1675 WHIRLWIND RD	A				
		WWD0055	135 N MAIN ST	A				
		WWD0056	3 TECHNOLOGY DRIVE	A				
		WWD0057	5 STERLING DRIVE	A				Y
		WWD0058	CHIMNEY HILL BLEEDER	A				Y
		WWD0059	MCGUIRE COURT	A				Y
		WWD0060	57 HALL RD	A				
		WWD0061	1145 OLD COLONY RD	A	Y			
		WWD0062	59 N PLAINS IND RD	A	Y			
		WWD0063	48 N PLAINS IND RD	A	Y			
		WWD0064	980 N MAIN ST EXT	A	Y			
		WWD0065	415 S CHERRY ST	A	Y			
		WWD0066	17 WEATHERSIDE DR	A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1480011	WALLINGFORD WATER DEPARTMENT	C	37,267	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			10,200				

Towns Served: NORTH HAVEN, WALLINGFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
		WWD0067	736 NORTH FARMS RD	A		1		
		WWD0068	159 GREIB ROAD	A		1		
		WWD0069	163 GREIB ROAD	A		1		
		WWD0070	53 N. PLAINS ROAD	A	Y			
00700	PISTAPAUG POND WTP ENTRY POINT	3	ENTRY POINT	A				
00701	OAK STREET WELLS #2 & #3 ENTRY POINT	3	EP-OAK STREET 2 & 3	A				
00702	RIDGELAND WELLFIELD - WELL#1 ENTRY POINT	3	EP-RIDGELAND WELL 1	A				
00703	BARNES CHLORINATION ST ENTRY POINT	3	EP-BARNES	A				
00704	OAK STR W #2 FINISHED (AIR STRIP. TOWER)	3	EP-OAK STR WELL #2	A				
00705	OAK STR W #3 FINISHED (GREENSAND)	3	EP-OAK STR WELL #3	A				
1390	OAK STREET WELL #2	2	OAK STREET WELL #2	A				
1391	OAK STREET WELL #3	2	OAK STREET WELL #3	A				
1392	WELL #1	2	WELL #1	A				
2270	MACKENZIE RESERVOIR	1	RESERVOIR	A				
2271	ULBRICH RESERVOIR	1	RESERVOIR	A				
2272	LANES POND	1	RESERVOIR	A				
2273	PISTAPAUG POND	1	PISTAPAUG POND	A				
289	PISTAPAUG POND WATER TREATMENT PLANT	5	EP - PISTAPAUG TP	A				
290	OAK STREET TREATMENT STATION	1	OAK STREET TREATMENT	A				
291	RIDGELAND TREATMENT STATION - WELL #1	5	IESWTR - ENTRY POINT	A				
30092	PISTAPAUG POND							
509	BARNES CHLORINATION STATION	5	IESWTR - ENTRY POINT	A				
54826	ULBRICH RAW WATER PUMP STATION							
54828	MACKENZIE RAW WATER PUMP STATION							
54830	SUNRISE CIRCLE PUMP STATION							
54832	HILLHOUSE STORAGE TANK							
54834	CHESHIRE ROAD PUMP STATION							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1480011	WALLINGFORD WATER DEPARTMENT	C	37,267	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			10,200				

Towns Served: NORTH HAVEN, WALLINGFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule Tier	Stage 2 Asbestos DBPR
54836	MASONIC GROUND STORAGE TANK					
54838	MASONIC STORAGE TANK					
54840	WESTSIDE STORAGE TANK					
54842	PARKER FARMS PUMP STATION					
54844	BARNES PUMP STATION					
54846	BARNES STORAGE TANK					
54848	CARPENTER STORAGE TANK					
54852	PISTAPaug POND RAW WATER PUMP STATION					
54854	PISTAPaug POND STORAGE TANK					

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: CLASS 2 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
ESPOSITO, THOMAS	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2018
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2017
PAWLOWSKI, JAY	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR IN TRAINING	6/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2018
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2018
VANSKI, RICHARD C.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2017
THIBODEAU, VINCENT J.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2018
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2019
GORMAN, CARL	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2017
		WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2018
EBER, BRUCE F.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2017
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2017
MAKUCH, GREGORY P.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2017
		WATER TREATMENT PLANT OPERATOR IN TRAINING	3/31/2019
MESKILL, RICHARD J.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2018
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2017
ZEMKE, DENNIS	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2017
GILLESPIE, ELIZABETH E.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2017
BRENNER, KATHLEEN A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2019
		WATER TREATMENT PLANT OPERATOR IN TRAINING	6/30/2019

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1480011	WALLINGFORD WATER DEPARTMENT	C	37,267	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			10,200				

Towns Served: NORTH HAVEN, WALLINGFORD

Certified Operator Information

Water System Facility: PISTAPaug POND WATER TREATMENT PLANT (WSF ID: 289)

Facility Classification: CLASS 4 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
MESKILL, RICHARD J.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2018
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2017
PAWLOWSKI, JAY	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2018
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2018
		WATER TREATMENT PLANT OPERATOR IN TRAINING	6/30/2019
ESPOSITO, THOMAS	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2017
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2018
THIBODEAU, VINCENT J.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2018
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2019
GORMAN, CARL	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2017
		WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2018
EBER, BRUCE F.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2017
		WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2017
ZEMKE, DENNIS	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2017
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2019

Water System Facility: OAK STREET TREATMENT STATION (WSF ID: 290)

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
ESPOSITO, THOMAS	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2018
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2017
THIBODEAU, VINCENT J.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2019
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2018

Water System Facility: RIDGELAND TREATMENT STATION - WELL #1 (WSF ID: 291)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
ESPOSITO, THOMAS	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2017
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2018
THIBODEAU, VINCENT J.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2018
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2019

Water System Facility: BARNES CHLORINATION STATION (WSF ID: 509)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
MESKILL, RICHARD J.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2018
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2017
THIBODEAU, VINCENT J.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2018
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2019

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1480011	WALLINGFORD WATER DEPARTMENT	C	37,267	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			10,200				

Towns Served: NORTH HAVEN, WALLINGFORD

Contact Information

Name		Organization			Job Title	
Mr. Richard J. Meskill		Wallingford Water Dept				
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
377 South Cherry Street				Wallingford	CT	06452
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-949-2666		203-949-2678		203-265-5055	waterquality@wallingfordct.gov	

Contact Role(s): **Administrative Contact**

Name		Organization			Job Title	
Mr. Neil H. Amwake		Town of Wallingford			General Manager	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
377 South Cherry St				Wallingford	CT	06492
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-949-2670		203-949-2678		860-922-6286	neil.amwake@wallingfordct.gov	

Contact Role(s): **Legal Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule