

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1630024	FIRST CONGREGATIONAL CHURCH OF WINDHAM	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
WINDHAM CENTER				1			
Towns Served: WINDHAM							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete		
	10/1/16 - 12/31/16		Complete		
	1/1/17 - 3/31/17				
	4/1/17 - 6/30/17				
	7/1/17 - 9/30/17				

Physical Parameters (PPS)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/17 - 3/31/17				
	4/1/17 - 6/30/17				
	7/1/17 - 9/30/17				

Physical Parameters (PPX)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete		
	10/1/16 - 12/31/16		Complete		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/16 - 12/31/16		Complete		
	1/1/17 - 12/31/17				
	1/1/18 - 12/31/18				

Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification</i>		<i>PN Certification</i>	
			<i>Required</i>	<i>Performed</i>	<i>Due to DPH</i>	<i>Received</i>
Total Coliform MCL Violation	4/1/09 - 6/30/09	2	7/29/2009		8/8/2009	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
22585	WELL	2	WELL	A				

Contact Information

Name	Organization	Job Title		
Pastor James Beesley				
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
4 Windham Center Road		Windham	CT	06280

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
CT1630024	FIRST CONGREGATIONAL CHURCH OF WINDHAM	NC	25	P	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
WINDHAM CENTER				1				
Towns Served: WINDHAM								
4 Windham Center Road Windham CT 06280								
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-423-7197								
Contact Role(s): Administrative Contact, Legal Contact								
Name			Organization			Job Title		
First Congregational Church of Windham C								
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
P. O. Box 102, 4 Windham Rd						Windham	CT	06280
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
Contact Role(s): Legal Contact, Owner								
Please note the following:								
1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.								
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.								
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.								

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1630074	ST PAULS EPISCOPAL CHURCH	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
27 PLAINS ROAD				1			
Towns Served: WINDHAM							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete
	1/1/17 - 3/31/17		
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

Physical Parameters (PPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/17 - 3/31/17		
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

Physical Parameters (PPX)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
22588	WELL	2	WELL	A				

Contact Information

Name			Organization			Job Title			
Mr. James Russel			St. Pauls Episcopal Church			Property Chair			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
P. O. Box 247						Windham		CT	06280
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-377-3687				860-377-3687	james.r.russel@yahoo.com				
Contact Role(s): Administrative Contact									

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source	
CT1630074	ST PAULS EPISCOPAL CHURCH	NC	25	P	GW	
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
27 PLAINS ROAD			1			
Towns Served: WINDHAM						

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1630104	GAUTHIER FIELD	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
ROUTE 14				1			
Towns Served: WINDHAM							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)			1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	4/1/17 - 6/30/17			
Physical Parameters (PPS)			1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	1/1/17 - 3/31/17			
	4/1/17 - 6/30/17			
	7/1/17 - 9/30/17			
Physical Parameters (PPX)			1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16			
	10/1/16 - 12/31/16			

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)			1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/16 - 12/31/16			
	1/1/17 - 12/31/17			
	1/1/18 - 12/31/18			

Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification</i>		<i>PN Certification</i>	
			<i>Required</i>	<i>Performed</i>	<i>Due to DPH</i>	<i>Received</i>
Distribution Turbidity MCL Violation	4/1/10 - 6/30/10	2	8/27/2010		9/6/2010	
Physical Parameters M&R Violation	4/1/16 - 6/30/16	3	10/6/2017		10/16/2017	
Total Coliform M&R Violation	4/1/16 - 6/30/16	3	11/23/2017		12/3/2017	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
			DOWNSTREAM WITHIN 5 SERVICE CON	A				
			UPSTREAM WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
22589	WELL	2	WELL	A				

Contact Information

Name		Organization			Job Title			
Ms. Pamela Bibeau		Windham Youth Organization			President			
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
P. O. Box 371						Windham	CT	06280
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-456-1727				860-456-1727	pwbhall2008@aol.com			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1630104	GAUTHIER FIELD	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
ROUTE 14				1			
Towns Served: WINDHAM							
800-450-1757		800-450-1757		wy00an2008@aol.com			
Contact Role(s):	Administrative Contact, Legal Contact						

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1630114	PLAINS ROAD PARK	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
PLAINS ROAD				1			
Towns Served: WINDHAM							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete		
	10/1/16 - 12/31/16		Complete		
	4/1/17 - 6/30/17				
	7/1/17 - 9/30/17				

Physical Parameters (PPS)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	4/1/17 - 6/30/17				
	7/1/17 - 9/30/17				

Physical Parameters (PPX)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete		
	10/1/16 - 12/31/16	10/1-10/30	Complete		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/16 - 12/31/16	4/1-10/30	Complete		
	1/1/17 - 12/31/17	4/1-10/30			
	1/1/18 - 12/31/18	4/1-10/30			

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
			DOWNSTREAM WITHIN 5 SERVICE CON	A				
			UPSTREAM WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
22590	WELL	2	WELL	A				

Contact Information

Name		Organization			Job Title			
Mr. Michael Paulhus		Windham Town Hall			First Selectman			
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
979 Main Street						Windham	CT	06280
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-465-3006		860-465-3012			wndmselectman@snet.net			
Contact Role(s):		Legal Contact, Owner						

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
CT1630114	PLAINS ROAD PARK	NC	25	P	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
PLAINS ROAD				1				
Towns Served: WINDHAM								
Name			Organization			Job Title		
Mr. Joseph F. Gardner			Windham Town Hall			Town Engineer		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
979 Main Street						Willimantic	CT	06226
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-465-3043		860-465-3012			windhamengineer@snet.net			
Contact Role(s): Administrative Contact								

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1630144	CLICK INC.	NC	30	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
41 CLUB ROAD				1			
Towns Served: WINDHAM							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete
	1/1/17 - 3/31/17		
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

Physical Parameters (PPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/17 - 3/31/17		
	4/1/17 - 6/30/17		
	7/1/17 - 9/30/17		

Physical Parameters (PPX)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete
	10/1/16 - 12/31/16		Complete

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/16 - 12/31/16		Complete
	1/1/17 - 12/31/17		
	1/1/18 - 12/31/18		

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
23030	WELL #1	2	WELL	A				
59324	BLADDER TANKS							
59686	TREATMENT PLANT							

Contact Information

Name			Organization			Job Title			
Maraiah Popeleski			Click Inc.			General Manager			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
P.O. Box 788						Willimantic		CT	06226
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-786-7907				860-428-3148	CLICKWILLIMANTIC@GMAIL.COM				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
CT1630144	CLICK INC.	NC	30	P	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
41 CLUB ROAD				1				
Towns Served: WINDHAM								
Contact Role(s): Administrative Contact								
Name		Organization			Job Title			
Phoebe Godfrey		Click Inc.			President			
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
P.O. Box 788						Willimantic	CT	06226
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-455-8395				956-236-6030	CLICKWILLIMANTIC@GMAIL.COM			
Contact Role(s): Legal Contact, Owner								
Name		Organization			Job Title			
Click Inc								
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
P.O. Box 788						Willimantic	CT	06226
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-428-3148					clickwillimantic@gmail.com			
Contact Role(s): Owner								

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1630154	NORTH WINDHAM FIRE DEPARTMENT	NC	25	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
603 BOSTON POST ROAD				1			
Towns Served: WINDHAM							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete		
	10/1/16 - 12/31/16		Complete		
	1/1/17 - 3/31/17				
	4/1/17 - 6/30/17				
	7/1/17 - 9/30/17				

Physical Parameters (PPS)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/17 - 3/31/17				
	4/1/17 - 6/30/17				
	7/1/17 - 9/30/17				

Physical Parameters (PPX)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete		
	10/1/16 - 12/31/16		Complete		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/16 - 12/31/16		Complete		
	1/1/17 - 12/31/17				
	1/1/18 - 12/31/18				

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
RESPOND TO SANITARY SURVEY	12/13/2015	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
23069	WELL #1	2	WELL #1	A				
59328	BLADDER TANKS							

Contact Information

Name	Organization	Job Title		
Mr. Miles Raymond	North Windham Fire Department			
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1630154	NORTH WINDHAM FIRE DEPARTMENT	NC	25	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
603 BOSTON POST ROAD				1			
Towns Served: WINDHAM							
P.O. Box 41			North Windham		CT	06256	
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-423-6432							

Contact Role(s): **Administrative Contact, Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1631214	APOLLO RESTAURANT AND PIZZA	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
685 WINDHAM ROAD				1			
Towns Served: WINDHAM							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete		
	10/1/16 - 12/31/16		Complete		
	1/1/17 - 3/31/17				
	4/1/17 - 6/30/17				
	7/1/17 - 9/30/17				

Physical Parameters (PPS)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/17 - 3/31/17				
	4/1/17 - 6/30/17				
	7/1/17 - 9/30/17				

Physical Parameters (PPX)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/16 - 9/30/16		Complete		
	10/1/16 - 12/31/16		Complete		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/16 - 12/31/16		Complete		
	1/1/17 - 12/31/17				
	1/1/18 - 12/31/18				

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
CROSS CONNECTION EXEMPTION	3/1/2019	

Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification</i>		<i>PN Certification</i>	
			<i>Required</i>	<i>Performed</i>	<i>Due to DPH</i>	<i>Received</i>
Total Coliform M&R Violation	7/1/13 - 9/30/13	3	3/27/2014		4/6/2014	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION	A				
			DOWNSTREAM WITHIN 5 SERVICE CON	A				
			UPSTREAM WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
53244	WELL 1A	2	WELL 1A	P				
59326	BLADDER TANKS							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1631214	APOLLO RESTAURANT AND PIZZA	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
685 WINDHAM ROAD				1			
Towns Served: WINDHAM							

Contact Information

Name			Organization			Job Title			
Mr. Chris Dalardhas									
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
P.O. Box 58			685 Windham Road			South Windham		CT	06266
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-456-2755									

Contact Role(s): **Administrative Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule