



# STATE OF CONNECTICUT

## DEPARTMENT OF PUBLIC HEALTH

August 18, 2008

Lee Jones  
Cultec, Inc.  
P.O. Box 280  
878 Federal Road  
Brookfield, CT 06804

Re: Recharger 330XL HD Leaching Chamber

Dear Mr. Jones:

This letter is in response to your June 16, 2008 correspondence concerning Cultec's renamed and reconfigured Recharger 330 leaching chamber. The chamber's old designation, Recharger 330, has been replaced with the new designation, Recharger 330XL HD. Your submittal included a new specification sheet dated 02-19-08, and your cover letter noted that the only physical change was an increase in the overall product length. The new unit length is now 102 inches, and the product has an installed length of 84 inches.

Since there were no changes to the overall product width, height or pipe opening invert, the assigned effective leaching area credits noted in the January 1, 2007 Technical Standards are still applicable. The next revision of the Technical Standards for Subsurface Sewage Disposal Systems will reference the new product designation. A copy of this letter will be sent electronically to our Code Advisory Committee and to local health departments in order to notify them of the changes to the Recharger leaching chamber.

Sincerely,

Robert W. Scully, PE  
Supervising Sanitary Engineer  
Environmental Engineering Program

c: Code Advisory Committee  
Local Health Departments

Phone: (860) 509-7296



Telephone Device for the Deaf: (860) 509-7191

410 Capitol Avenue - MS # 51-SEW

P.O. Box 340308 Hartford, CT 06134

*Affirmative Action / An Equal Opportunity Employer*