

READINESS CENTER, CAMP RELL
NIANTIC, CT
PROJECT: BI-Q-617

BID OPENING	1:00 P.M.	OCTOBER 24, 2007
ADDENDUM NO. 1	DATE OF ADDENDUM	AUGUST 31, 2007

Item 1

On Drawing S-104:

Note #4, remove datum elevation 53'-4"

Add Top of Steel 52'-9-1/2" for stair #1 at Elevation Key Plan.

Add Top of Steel 52'-0" for stair #2 at Elevation Key Plan.

Item 2

On Drawing S-105:

Add TS 6 x 6 x 3/8" at elevation 58'-8" on line F.

Add TS 6 x 6 x 3/8" on line A, see architectural plans for elevation.

Item 3

On Drawing S-501:

Delete the steel lintel schedule and note and the typical lintel details. Replace with Drawing No. S-SK-1 (attached to this amendment).

Item 4

On Drawing A-101:

Add a 4" wythe of cmu at north side of north wall of stair #5. Align with brick above.

Item 5

On Drawing A-201:

Relocate keying of Detail 3/A313 on east elevation from south side of column line 10 to north side of column line 10.