

**UTILITY IMPROVEMENTS  
SOMERS CORRECTIONAL COMPLEX  
ENFIELD/SOMERS, CONNECTICUT  
PROJECT: BI- JA - 438**

<b>BID OPENING</b>	<b>1:00 P.M.</b>	<b>May 7, 2008</b>
<b>ADDENDUM NUMBER 1</b>	<b>DATE OF ADDENDUM</b>	<b>May 1, 2008</b>

The following clarifications are applicable to drawings and specifications for the project referenced above.

Item 1

The bid opening will be changed from 1:00 PM on May 7, 2008 to 1:00 PM on May 14, 2008.

Item 2

The Water Main work depicted on Sheets PP-11, PP-12, and DN-1 must be completed between September 1, 2008 and April 1, 2009 for this project. No work will be permitted on the Water Main at any other time.

Item 3

In the Bid Proposal Form, page 14, Item 02665A shall be modified as follows:

DELETE: Installation of pipe & Furnish & Install. Of Fittings (CT Public Works will furnish pipe but not fittings).

CLARIFICATION: The contractor's price shall include the cost of furnishing and installing the Water Main.

Item 4

On sheets PP-6 and PP-10 of the Contract Drawings:

DELETE: "Install 4' Wide Rip-Rap Channel"

SUBSTITUTE: "Install 8' Wide Rip-Rap Channel"

Item 5

On sheet DN-2 of the Contract Drawings:

MODIFY: The Riprap Channel Detail.

DELETE: The 12'-0" dimension.