

Connecticut DEP Public Record - Summary Information Underground Storage Tanks (USTs)

General Information

Public Record Reporting Period: 2018

Total Number Of UST Facilities: 2134

Total Number Of USTs: 5619

Summary Information For On-Site Inspections

Number Of UST Facilities Inspected: 503

Inspection Period Dates: 10-1-17 To: 9-30-18

Percent Compliance (Combined Measure): 82%

[NOTE: TANK, FACILITY, AND ON-SITE INSPECTION INFORMATION IS BASED ON INSPECTIONS OF UST FACILITIES REGULATED UNDER SECTION 22A-449(D)-101 THROUGH 113 ONLY; HEATING OIL USTs ARE NOT INCLUDED. ON-SITE INSPECTIONS MEASURE COMPLIANCE WITH STATE OF CONNECTICUT AND U.S. EPA REGULATIONS AND LAWS GOVERNING THE PREVENTION AND DETECTION OF PETROLEUM RELEASES OR DISCHARGES.]

Summary Information For Releases

Number Of Confirmed UST Releases: 107

Release Reporting Period Dates: October 1, 2017 To: September 30, 2018

Summary Information For Release Sources And Causes

SOURCE			CAUSE													
			Spill		Overfill		Phys/Mech Damage		Corrosion		Install Problem		Other		Unknown	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	13	12	0	0		0	2	15	5	38	0	0	0	0	6	46
Piping	4	4	0	0		0	2	50	0	0	0	0	0	0	2	50
Dispenser	10	9	0	0	1	10	5	50	0	0	0	0	0	0	4	40
STP*	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Delivery Problem	1	1	0	0	1	100	0	0	0	0	0	0	0	0	0	0
Other	1	1	0	0	0	0	1	100	0	0	0	0	0	0	0	0
Unknown**	78	73	0	0	0	0	0	0	0	0	0	0	0	0	78	100
Totals	107	100	0	0	2	2	10	9	5	5	0	0	0	0	90	84

= number of release per source and/or cause, source % = percent of total number of releases, cause % = percent of total number of releases per source

*STP means Submersible Turbine Pump

**Unknown indicates releases where the exact source was not able to be determined (i.e. historic releases)

[NOTE: RELEASE, SOURCE AND CAUSE INFORMATION IS BASED ON REPORTED RELEASES AT UST FACILITIES REGULATED UNDER SECTION 22A-449(D)-101 THROUGH 113. SOURCE AND CAUSE DATA WERE COMPILED FROM DATA COLLECTED IN THE COURSE OF INVESTIGATING UST SYSTEM RELEASES AND USING THE STORAGE TANK AND PCB ENFORCEMENT UNIT AUTOPSY REPORTING FORM.]

To obtain site-specific UST information on compliance and releases or information on this page, please contact the Storage Tank and PCB Enforcement Unit at (860) 424-3374 or e-mail lori.saliby@ct.gov or write to:

Department of Energy and Environmental Protection
Bureau of Materials Management and Compliance Assurance
Storage Tank and PCB Enforcement Unit
79 Elm Street
Hartford, CT 06106-5127

Last Updated 12/14/2018